

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY, AJMER (Raj)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech./ 2025-26/ 212

Date: 15.5.2025

Not for Legal Purpose

To,

Principal
Arya Bhatta world School
Kayad Road Chachiyawas
Ajmer

District: AJMER
Tehsil: Ajmer

Reference: Your Letter No.- 302 Dated 22.04.2025

Sample Collected by :- Abhishek Tiwari (Staff)

Date of Receipt :- 23.04.2025

**Sample was not Collected
by Laboratory**

Lab Sample No.	IS10500:2012		P-7
Source :			Ro Treated Water
Source Location:	Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	Arya Bhatta World School
Town / Village			Ajmer
Date of Collection→			22.04.2025
Date of Examination→			23.04.2025
Test Parameter↓			Results↓
1 pH Value	6.5 - 8.5	No Relaxation	8.12
2 Turbidity (NTU) Max	1	5	0.8
3 Colour (Hazen Units), Max	5	15	Nil
4 Odour	Agrreable		Agrreable
5 Total Alkalinity (as CaCO_3) mg/l, Max	200	600	100
6 Total Hardness (as CaCO_3) mg/l, Max	200	600	60
7 Chlorides as Cl^- mg/l, Max	250	1000	120
8 Fluorides as F^- mg/l, Max	1.0	1.5	0.3
9 Nitrate as NO_3^- mg/l, Max	45	No Relaxation	5
10 Total Dissolved Solids(T.D.S.) mg/l, Max	500	2000	450
11 Residual Chlorine	0.2	1.0	Nil
	Applicable only when water is Chlorinated		

Note: 1. The sample was not collected by this laboratory.

2. This Report is not for legal Purpose.

*Dr. A. S. Sharma
16.05.25*

Archana Mathur
(Dr. Archana Mathur)
Superintending Chemist
P.H.E.D. Regional Lab., Ajmer

PRINCIPAL
ARYABHATTA WORLD SR. SEC. SCHOOL
KAYAD ROAD, CHACHIYAWAS, AJMER

✓

ARYABHATTA ACADEMIC SOCIETY

Archana Mathur

SECRETARY

APPENDIX - XIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 730

Dated: 15/05/2025

It is certified that an inspection team headed by VIKAS SAH

From JEN PHED CITY SUB DIV III FILTER PLANT

Inspected the Aryabhatta World Sr. Sec. School, Kayad Road, Chachiyawas, Ajmer on 15/05/2025

Checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/state/U.T, Govt. The above is valid for a period of One year

Signature with Seal: कानूनी अमियता
जैन स्वा. अमित सिंहाम

Name: VIKAS SAH

Designation: JEN

To

PRINCIPAL

Aryabhatta World Sr. Sec. School ARYABHATTA WORLD SR. SEC. SCHOOL
KAYAD ROAD, CHACHIYAWAS, AJMER
Kayad Road, Chachiyawas, Ajmer

Dr. A.K. Singh
15.05.25

ARYABHATTA ACADEMIC SOCIETY

Anupasheth
SECRETARY